

Appendix V
Detailed Status Report of
Recommendations
Since 2014

Chapter Name	Department/ Agency	Year	Volume	Chapter	Par.	Recommendation	Self Reported Status
Data Centre Power Interruption	NB Internal Services Agency (Service New Brunswick)	2014	2	3	71	We recommend the NBISA identify critical infrastructure components and establish replacement plans. We also recommend the NBISA develop and implement a refresh program for such equipment.	Implemented
Data Centre Power Interruption	Office of the Chief Information Officer	2014	2	3	72	We recommend the Office of the Chief Information Officer (OCIO) define roles and responsibilities related to development of corporate IT strategic development for all departments and take recommendations to cabinet that clarify corporate IT roles and responsibilities and ensure strategic goals of the OCIO, the NBISA and the departments are aligned.	Not Implemented
Data Centre Power Interruption	NB Internal Services Agency (Service New Brunswick)	2014	2	3	81	We recommend the NBISA prepare threat risk assessments, as part of its corporate IT continuity planning, and take recommendations to cabinet to further mitigate risk of failure of IT services.	Implemented
Data Centre Power Interruption	NB Internal Services Agency (Service New Brunswick)	2014	2	3	82	We recommend the NBISA develop a data centre availability strategy to provide a level of service congruent with industry standards. We also recommend NBISA develop a monitoring process to ensure strategies are implemented to achieve the strategic vision.	Implemented
Data Centre Power Interruption	Office of the Chief Information Officer	2014	2	3	92	We recommend the OCIO, in consultation with departments, develop a government-wide IT continuity plan, which considers all aspects of government programs, services and operations. This plan should be tested annually to ensure its adequacy.	Not Implemented
Data Centre Power Interruption	Office of the Chief Information Officer	2014	2	3	93	We recommend the OCIO, as part of IT continuity planning, obtain an assessment of services from each department to identify and prioritize critical systems, which require uninterrupted IT continuity.	Not Implemented

Chapter Name	Department/ Agency	Year	Volume	Chapter	Par.	Recommendation	Self Reported Status
Data Centre Power Interruption	NB Internal Services Agency (Service New Brunswick)	2014	2	3	94	We recommend the NBISA, in consultation with departments, develop a disaster recovery plan, which prioritizes the restoration of government IT systems.	Not Implemented